

DEPARTMENT OF WATER RESOURCES

1416 NINTH STREET, P.O. BOX 942836
SACRAMENTO, CA 94236-0001
(916) 653-5791



September 20, 2018

Craig C. Platt
Director of Public Works
California City
7800 Moss Avenue
California City, CA 93505

Subject: The 2017 Validated Water Loss Audit Report

Dear Mr./Ms. Platt:

The Department of Water Resources (DWR) has reviewed California City's 2017 Validated Water Loss Audit Report. California Water Code (CWC) Section 10608.34 directs DWR to review all submitted validated water loss audit reports. Our review finds that the report addresses the code requirements. The validated water loss audit reports are posted at our website: <https://wuedata.water.ca.gov>.

If you have any questions regarding water loss audits and reports, please contact Todd Thompson at todd.thompson@water.ca.gov or 916-651-9255

Sincerely

A handwritten signature in black ink, appearing to read "Vicki Lake".

Vicki Lake
Unit Chief
Urban Water Use Efficiency
(916) 651-0740

Electronic cc:

Water Audit Level 1 Validation Review Document

Audit Information:

Utility: California City PWS ID: 1510032
 System Type: Potable Audit Period: Calendar 2017
 Utility Representation: Toby Layton, Art VanDang
 Validation Date: 10/5/2018 Call Time: 8:30am Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 53 Data Validity Band (Level): Band III (51-70)
 ILI: 3.39 Real Loss: 1,741.72 (gal/mile-main/day) Apparent Loss: 8.23 (gal/conn/day)
 Non-revenue water as percent of cost of operating system: 5.5%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

Validator Information:

Water Audit Validator: Larry Lewison, Will Jernigan P.E. Validator Qualifications: Contractor for California Water Loss TAP

Validator Provided



CAVANAUGH

Stewardship Through Innovation

#	AWWA Water Audit Input	Code	Final DVG	Basis on Input Derivation	Basis on Data Validity Grade
1	Volume from Own Sources	VOS	4	Supply meter profile: Total of 6 groundwater wells used in varying degrees for 2017. Water purchased from AVEK heavily supplements peak months. Volumes are tracked by daily manual reads and compared to SCADA recorded volumes. Meters are scheduled to be tested by manufacturer in 2018 and SCE is scheduled to perform pump efficiency tests in 2018. VOS input derived from: Manual reads from production meters as archived. Comments: Input derivation from supporting documents confirmed. Exclusion of non-potable volumes confirmed.	Percent of own supply metered: 100% Signal calibration frequency: None. Volumetric testing frequency: None. Volumetric testing method: n/a. Percent of own supply tested and/or calibrated: 0%. Comments: Meters replaced in 2016 and are reliably maintained. No testing in 2017. In situ testing is planned for 2018.
2	VOS Master Meter & Supply Error Adjustment	VOS MMSEA	2	Input derivation: Left blank in absence of available test data. Net storage change included in MMSEA input: No. Comments: 5 total storage tanks	Supply meter read frequency: Daily. Supply meter read method: Manual and automatic logging. Frequency of data review for trends & anomalies: Monthly. Storage levels monitored in real-time: Yes. Comments: No additional comments.
3	Water Imported	WI	2	Import meter profile: Purchase water from AVEK used all 12 months. WI input derived from: Totalization of volumes per redundant meter reads by utility. They read on a monthly basis, AVEK reviews the data once a month; they cross check their reads with invoices. Not connected to SCADA. Comments: Input derivation from supporting documents confirmed. Exclusion of non-potable volumes confirmed.	Percent of import supply metered: 100% Signal calibration frequency: Unsure. Volumetric testing frequency: Unsure. Volumetric testing method: Unsure. Percent of import supply volumetrically tested: n/a. Comments: No additional comments.
4	WI Master Meter & Supply Error Adjustment	WI MMSEA	2	Input derivation: Left blank in absence of available test data. Comments: No additional comments.	Import meter read frequency: Monthly. Import meter read method: Manual. Frequency of data review for trends & anomalies: Monthly. Comments: No additional comments.
5	Water Exported	WE	n/a	Comments: No other entities to tie into, so no connections exist.	
6	WE Master Meter & Supply Error Adjustment	WE MMSEA	n/a		
7	Billed metered	BMAC	6	Customer meter profile: Age profile: Oldest 30 to 40 years old, newest < 1 year. Currently about 60% completed with full meter replacement project. Reading system: Manual (older meters), AMR (newer meters)	Percent of customers metered: 100% Small meter testing policy: Reactive - complaint based or flagged-consumption testing only. Have a new bench test and

#	AWWA Water Audit Input	Code	Final DVG	Basis on Input Derivation	Basis on Data Validity Grade
				<p>Read frequency: Monthly (3rd party). Comments: Lag-time correction is not employed in input derivation. Input derivation from supporting documents confirmed. Exclusion of non-potable volumes confirmed. Consumption increased considerable in 2017 thought to be directly related to new meters installed. Have a third-party agency to manually read meters until new AMR system is fully complete. Meter changeout proxy for testing will be valid through 2018 only. Currently filling City owned lake with drinking water and billed to parks and recreation.</p>	<p>now test the retired old meters and some new meters before installation. Number of small meters tested/year: 250 Large meter testing policy: Reactive - complaint based or flagged-consumption testing only. Number of large meters tested/year: 0 Meter replacement policy: Ongoing via meter conversion project at ~10% each year. Number of replacements/year: 626 Billing data auditing: Standard billing QC, plus review of volumes by use type each billing cycle. Financial auditor performs sampling review on select accounts each year. Comments: DVG of 6 based on using the meter changeout project as proxy for meter testing. Limited by routine auditing of detailed statistics.</p>
8	Billed unmetered	BUAC	n/a	Comments: None reported for 2017.	
9	Unbilled metered	UMAC	n/a	Comments: All municipal accounts are read and billed.	
10	Unbilled unmetered	UUAC	5	<p>Profile: Operational flushing and fire department usage. Comments: Custom California default of 0.25%xAWS utilized.</p>	<p>Comments: Default grade applied. Consider expanding your current tracker of flushing volumes to cover all applicable uses of unbilled, unmetered. No leak volumes applied here.</p>
11	Unauthorized consumption	UC	5	Comments: Default input applied.	Comments: Default grade applied.
12	Customer metering inaccuracies	CMI	4	<p>See BMAC comments regarding meter testing & replacement activities. Input derivation: Inferred value was modified from 1.5% to 1.25% due to additional new meter installations. Comments: Consider using existing meter test results to develop a calculated volume for this input.</p>	<p>Characterization of meter testing: Routine (proactive), but not fully representative. Characterization of meter replacement: Routine (proactive) but limited. Comments: Retired meters are being tested.</p>
13	Systematic data handling errors	SDHE	5	Comments: Default input applied. After discussion about the provided input number, it was determined input volume represented leak volumes particularly from a transmission main break during 2017. Input was changed to the default input.	Comments: Default grade applied.



CAVANAUGH

Stewardship Through Innovation

#	AWWA Water Audit Input	Code	Final DVG	Basis on Input Derivation	Basis on Data Validity Grade
14	Length of mains	Lm	6	Input derivation: Totaled from CAD based map and old paper as-builts (new infrastructure from approximately last 12 years is in GIS, older areas are paper records). Hydrant leads included: Yes. Comments: No additional comments.	Mapping format: Digital (new areas only). Asset management database: Not currently in place. Map updates & field validation: Accomplished through normal work order processes. Comments: No additional comments.
15	Number of service connections	Ns	7	Input derivation: Standard report run from billing system (4,453 active connections, 756 inactive, totaling to 5,209). Basis for database query: Account ID - non-premise based. Comments: Removed 102 services at trailer park, replaced by master meter.	CIS updates & field validation: Accomplished through normal meter reading processes. Estimated error of total count within: 3%. Comments: No additional comments.
16	Ave length of cust. service line	Lp	10	Comments: Default input and grade applied, as customer meters are typically located at the property boundary given California climate.	
17	Average operating pressure	AOP	5	Number of zones, general profile: 1 major gravity zone 90%, 6 smaller pumped zones (so 7 total zones). Typical pressure range: 50-90 psi. Input derivation: Rudimentary estimate. Comments: Consider using existing SCADA information from pressure transducers in addition to field test pressure data to calculate a weighted average operating pressure.	Extent of static pressure data collection: n/a. Characterization of real-time pressure data collection: Basic - telemetry or pressure logging at boundary points (supply locations, tanks, PRVs, boosters). Hydraulic model: In place, but unsure of use and date of last field calibration. Comments: No additional comments.
18	Total annual operating cost	TAOC	10	Input derivation: From official financial reports. Comments: Confirmed costs limited to water only, and water debt service included.	Frequency of internal auditing: Annually. Frequency of third-party CPA auditing: Annually. Comments: No additional comments.
19	Customer retail unit cost	CRUC	8	Input derivation: Total consumptive revenue divided by Billed Metered Authorized Consumption. Commercial sewer charges are based on water meter readings. Sewer revenues are incorporated into calculation. Comments: Calculated from total water sales and commercial sewer sales divided by total billed metered volume.	Characterization of calculation: Composite via simple rate structure with only a single rate. Input calculations have not been reviewed by an M36 water loss expert. Comments: No additional comments.
20	Variable production cost	VPC	4	Supply profile: Own sources and import supply. Primary costs included: Treatment chemicals and supply & distribution power. Secondary costs included: None currently included.	Characterization of calculation: Primary costs only. Input calculations have not been reviewed by an M36 water loss expert. Comments: No additional comments.

#	AWWA Water Audit Input	Code	Final DVG	Basis on Input Derivation	Basis on Data Validity Grade
				Comments: Primary costs only. Power plus Chemical for VOS and purchase water from AVEK.	

Key Audit Metrics

(~) VALIDITY Data Validity Score: 53 Data Validity Band (Level): Band III (51-70)
 (#) VOLUME ILLI: 3.39 Real Loss: 1741.72 (gal/mile/day) Apparent Loss: 8.23 (gal/conn/day)
 (\$) VALUE Annual Cost of Apparent Losses: \$128,008 Annual Cost of Real Losses: \$91,337

Infrastructure & Water Loss Management Practices:

Infrastructure age profile: 40-60 years old (started in 1960s). Infrastructure replacement policy (current, historic): Ongoing replacement.
 Estimated main failures/year: 65 Estimated service failures/year: 265
 Extent of proactive leakage management: They find leaks very easily due to non-absorbent ground (clay), so leaks come to surface quickly.
 Other water loss management comments: No additional comments.

Comments on Audit Metrics & Validity Improvements

The Infrastructure Leakage Index (ILI) of 3.39 describes a system that experiences leakage at 3.39 times the modeled technical minimum for its system characteristics.

The Data Validity Score falling within Band III (51-70) suggests that next steps may be focused simultaneously on improving data reliability and evaluating cost-effective interventions for water & revenue loss recovery. Opportunities to improve the reliability of audit inputs and outputs include:

- Improved understanding of Supply Meter (Own and Import) Master Meter Error: consider adopting or increasing the rigor of a source meter volumetric testing and calibration program, informed by the guidance provided in AWWA Manual M36 – Appendix A.
- Improved estimation of CMI: consider a customer meter testing program which tests a sample of random meters whose stratification (by size, age, or other characteristics) represents the entire customer meter stock.
- Temporal alignment of Billed Metered Authorized Consumption with Water Supplied: consider pro-rating the first and last months of the audit period to better align consumption with actual dates of use, and using read date as basis for reporting.
- Customized estimate of Unbilled Unmetered Authorized Consumption: consider producing itemized, agency-specific estimates of unbilled unmetered (operational) uses, rather than using the default. Ensure leakage estimates are excluded.
- Level 2 validation on raw data for Billed Metered Authorized Consumption to determine and resolve any instances of potable volume duplication or non-potable volume inclusion.

Further Recommendations

Since Data Validity Score is >50, consider follow-on implementations as described in the AWWA M36 Manual, once the annual water audit is established:

- Conduct a Real Loss Component Analysis to develop your leakage profile.
- Conduct an Apparent Loss Component Analysis to develop your apparent loss profile.
- Cost-benefit analysis & target setting for water loss components.
- Design & implement water loss control program for cost-effective interventions.

AWWA Free Water Audit Software: Reporting Worksheet

WAS v5.0

American Water Works Association

[?](#) Click to access definition
[+](#) Click to add a comment

Water Audit Report for: **California City (1510032)**
 Reporting Year: **2017** 1/2017 - 12/2017

Please enter data in the white cells below. Where available, metered values should be used; if metered values are unavailable please estimate a value. Indicate your confidence in the accuracy of the

All volumes to be entered as: ACRE-FEET PER YEAR

To select the correct data grading for each input, determine the highest grade where

WATER SUPPLIED

←----- Enter grading in column 'E' and 'J' ----->

Volume from own sources:	<input type="button" value="+"/> <input type="button" value="?"/> 4	2,886.808	acre-ft/yr
Water imported:	<input type="button" value="+"/> <input type="button" value="?"/> 2	406.626	acre-ft/yr
Water exported:	<input type="button" value="+"/> <input type="button" value="?"/> n/a		acre-ft/yr

Master Meter and Supply Error Adjustments

Pcnt:	<input type="button" value="+"/> <input type="button" value="?"/> 3	<input type="radio"/> <input type="radio"/>	Value:	<input type="text"/>	acre-ft/yr
	<input type="button" value="+"/> <input type="button" value="?"/> 2	<input checked="" type="radio"/> <input type="radio"/>		<input type="text"/>	acre-ft/yr
	<input type="button" value="+"/> <input type="button" value="?"/> 1	<input type="radio"/> <input type="radio"/>		<input type="text"/>	acre-ft/yr

Enter negative % or value for under-registration
 Enter positive % or value for over-registration

WATER SUPPLIED: **3,293.434** acre-ft/yr

AUTHORIZED CONSUMPTION

Billed metered:	<input type="button" value="+"/> <input type="button" value="?"/> 6	2,624.575	acre-ft/yr
Billed unmetered:	<input type="button" value="+"/> <input type="button" value="?"/> n/a		acre-ft/yr
Unbilled metered:	<input type="button" value="+"/> <input type="button" value="?"/> n/a		acre-ft/yr
Unbilled unmetered:	<input type="button" value="+"/> <input type="button" value="?"/> 5	8.234	acre-ft/yr

Click here: [?](#)
 for help using option
 buttons below

Pcnt: Value:
 8.234 acre-ft/yr

Use buttons to select
 percentage of water
 supplied
 OR
 value

AUTHORIZED CONSUMPTION: **2,632.809** acre-ft/yr

WATER LOSSES (Water Supplied - Authorized Consumption)

660.625 acre-ft/yr

Apparent Losses

Unauthorized consumption: **8.234** acre-ft/yr
 Default option selected for unauthorized consumption - a grading of 5 is applied but not displayed

Customer metering inaccuracies: 4 **33.222** acre-ft/yr
 Systematic data handling errors: **6.561** acre-ft/yr

Default option selected for Systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: **48.017** acre-ft/yr

Pcnt: Value:
 0.25% acre-ft/yr

1.25% acre-ft/yr
 0.25% acre-ft/yr

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: **612.608** acre-ft/yr

WATER LOSSES: **660.625** acre-ft/yr

NON-REVENUE WATER

NON-REVENUE WATER: **668.859** acre-ft/yr

= Water Losses + Unbilled Metered + Unbilled Unmetered

SYSTEM DATA

Length of mains: 6 314.0 miles
 Number of active AND inactive service connections: 7 5,209
 Service connection density: **17** conn./mile main

Are customer meters typically located at the curbside or property line?

Average length of customer service line: (length of service line, beyond the property boundary, that is the responsibility of the utility)

Average length of customer service line has been set to zero and a data grading score of 10 has been applied

Average operating pressure: 5 65.0 psi

COST DATA

Total annual cost of operating water system: 10 \$4,034,161 \$/Year
 Customer retail unit cost (applied to Apparent Losses): 8 \$8.50 \$/100 cubic feet (ccf)
 Variable production cost (applied to Real Losses): 4 \$1,064.22 \$/acre-ft Use Customer Retail Unit Cost to value real losses

WATER AUDIT DATA VALIDITY SCORE:

*** YOUR SCORE IS: 53 out of 100 ***

A weighted scale for the components of consumption and water loss is included in the calculation of the Water Audit Data Validity Score

PRIORITY AREAS FOR ATTENTION:

Based on the information provided, audit accuracy can be improved by addressing the following components:

- 1: Volume from own sources
- 2: Customer metering inaccuracies
- 3: Variable production cost (applied to Real Losses)

AWWA Free Water Audit Software v5.0

American Water Works Association Copyright © 2014. All Rights Reserved.

This spreadsheet-based water audit tool is designed to help quantify and track water losses associated with water distribution systems and identify areas for improved efficiency and cost recovery. It provides a "top-down" summary water audit format, and is not meant to take the place of a full-scale, comprehensive water audit format. Auditors are strongly encouraged to refer to the most current edition of AWWA M36 Manual for Water Audits for detailed guidance on the water auditing process and targeting loss reduction levels.

The spreadsheet contains several separate worksheets. Sheets can be accessed using the tabs towards the bottom of the screen, or by clicking the buttons below.

Please begin by providing the following information

Name of Contact Person:

Email Address:

Telephone | Ext.:

Name of City / Utility:

City/Town/Municipality:

State / Province:

Country:

Year:

Audit Preparation Date:

Volume Reporting Units:

PWSID / Other ID:

The following guidance will help you complete the Audit

All audit data are entered on the [Reporting Worksheet](#)

Value can be entered by user

Value calculated based on input data

These cells contain recommended default values

Use of Option (Radio) Buttons: 0.25%

Pcnt:

Value:

Select the default percentage by choosing the option button on the left

To enter a value, choose this button and enter a value in the cell to the right

The following worksheets are available by clicking the buttons below or selecting the tabs along the bottom of the page

Instructions

The current sheet. Enter contact information and basic audit details (year, units etc)

Reporting Worksheet

Enter the required data on this worksheet to calculate the water balance and data grading

Comments

Enter comments to explain how values were calculated or to document data sources

Performance Indicators

Review the performance indicators to evaluate the results of the audit

Water Balance

The values entered in the Reporting Worksheet are used to populate the Water Balance

Dashboard

A graphical summary of the water balance and Non-Revenue Water components

Grading Matrix

Presents the possible grading options for each input component of the audit

Service Connection Diagram

Diagrams depicting possible customer service connection line configurations

Definitions

Use this sheet to understand the terms used in the audit process

Loss Control Planning

Use this sheet to interpret the results of the audit validity score and performance indicators

Example Audits

Reporting Worksheet and Performance Indicators examples are shown for two validated audits

Acknowledgements

Acknowledgements for the AWWA Free Water Audit Software v5.0

If you have questions or comments regarding the software please contact us via email at: wlc@awwa.org



AWWA Free Water Audit Software: System Attributes and Performance Indicators

Water Audit Report for: **California City (1510032)**
Reporting Year: **2017** **1/2017 - 12/2017**

***** YOUR WATER AUDIT DATA VALIDITY SCORE IS: 53 out of 100 *****

System Attributes:

Apparent Losses:	48.017	acre-ft/yr
+ Real Losses:	612.608	acre-ft/yr
= Water Losses:	660.625	acre-ft/yr
? Unavoidable Annual Real Losses (UARL):	180.57	acre-ft/yr
Annual cost of Apparent Losses:	\$177,790	
Annual cost of Real Losses:	\$651,950	

Valued at **Variable Production Cost**
Return to Reporting Worksheet to change this assumption

Performance Indicators:

Financial:	Non-revenue water as percent by volume of Water Supplied:	20.3%
	Non-revenue water as percent by cost of operating system:	20.8%
Operational Efficiency:	Apparent Losses per service connection per day:	8.23 gallons/connection/day
	Real Losses per service connection per day:	N/A gallons/connection/day
	Real Losses per length of main per day*:	1,741.72 gallons/mile/day
	Real Losses per service connection per day per psi pressure:	N/A gallons/connection/day/psi
	From Above, Real Losses = Current Annual Real Losses (CARL):	612.61 acre-feet/year
	? Infrastructure Leakage Index (ILI) [CARL/UARL]:	3.39

* This performance indicator applies for systems with a low service connection density of less than 32 service connections/mile of pipeline



AWWA Free Water Audit Software: User Comments

WAS v5.0
American Water Works Association.
Copyright © 2014. All Rights Reserved.

Use this worksheet to add comments or notes to explain how an input value was calculated, or to document the sources of the information used.

General Comment:	
Audit Item	Comment
<u>Volume from own sources:</u>	
<u>Vol. from own sources: Master meter error adjustment:</u>	
<u>Water imported:</u>	
<u>Water imported: master meter error adjustment:</u>	
<u>Water exported:</u>	
<u>Water exported: master meter error adjustment:</u>	
<u>Billed metered:</u>	
<u>Billed unmetered:</u>	
<u>Unbilled metered:</u>	

Audit Item	Comment
<u>Unbilled unmetered:</u>	
<u>Unauthorized consumption:</u>	
<u>Customer metering inaccuracies:</u>	
<u>Systematic data handling errors:</u>	
<u>Length of mains:</u>	
<u>Number of active AND inactive service connections:</u>	To date we have a total of 4453 active accounts and a total of 756 inactive accounts
<u>Average length of customer service line:</u>	
<u>Average operating pressure:</u>	
<u>Total annual cost of operating water system:</u>	
<u>Customer retail unit cost (applied to Apparent Losses):</u>	Calculated based on \$52.99 per 900 cu ft to generate a simple average plus commercial sewer at \$2.81 per cu ft
<u>Variable production cost (applied to Real Losses):</u>	Composite of primary cost only. Power plus chemical for VOS to purchase water from AVEK



AWWA Free Water Audit Software: Water Balance

WAS v5.0
American Water Works Association.






Water Audit Report for: **California City (1510032)**
 Reporting Year: **2017**
 Data Validity Score: **53**
 1/2017 - 12/2017

Own Sources (Adjusted for known errors)	2,886.808	System Input 3,293.434	Water Supplied 3,293.434	Water Exported 0.000	Authorized Consumption 2,632.809	Billed Authorized Consumption 2,624.575	Billed Water Exported Billed Metered Consumption (water exported is removed) 2,624.575	Revenue Water 0.000
	Water Imported 406.626							
						Apparent Losses 48.017	Unauthorized Consumption 8.234	Non-Revenue Water (NRW) 668.859
						Real Losses 612.608	Customer Metering Inaccuracies 33.222	
							Systematic Data Handling Errors 6.561	
							Leakage on Transmission and/or Distribution Mains <i>Not broken down</i>	
							Leakage and Overflows at Utility's Storage Tanks <i>Not broken down</i>	
							Leakage on Service Connections <i>Not broken down</i>	

The graphic below is a visual representation of the Water Balance with bar heights proportional to the volume of the audit components

Water Audit Report for: California City (1510032)
Reporting Year: 2017
Data Validity Score: 53

Show me the VOLUME of Non-Revenue Water
 Show me the COST of Non-Revenue Water



The grading assigned to each audit component and the corresponding recommended improvements and actions are highlighted in yellow. Audit accuracy is likely to be improved by prioritizing those items shown in red

Grading >>>	WATER SUPPLIED										
	n/a	1	2	3	4	5	6	7	8	9	10
<p>Volume from own sources:</p> <p>Improvements to attain higher data grading for "Volume from own Sources" component</p>	<p>Select this grading only if purchases/imports all of its water resources (i.e. has no sources of its own)</p>	<p>Less than 25% of water production sources are metered, remaining sources are estimated. No regular meter accuracy testing or electronic calibration conducted.</p>	<p>25% - 50% of treated water production sources are metered, other sources estimated. No regular meter accuracy testing or electronic calibration conducted.</p>	<p>Conditions between 2 and 4</p>	<p>50% - 75% of treated water production sources are metered, other sources estimated. Occasional meter accuracy testing or electronic calibration conducted.</p>	<p>Conditions between 4 and 6</p>	<p>At least 75% of treated water production sources are metered, or at least 80% of the source flow is derived from metered sources. Meter accuracy testing and/or electronic calibration of related instrumentation is conducted annually. Less than 25% of tested meters are found outside of +/- 6% accuracy.</p>	<p>Conditions between 6 and 8</p>	<p>100% of treated water production sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually, with less than 10% found outside of +/- 3% accuracy. Procedures are reviewed by a third party knowledgeable in the M36 methodology.</p>	<p>Conditions between 8 and 10</p>	<p>100% of treated water production sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.</p>
<p>Improvements to attain higher data grading for "Volume from own Sources" component</p>	<p>Select n/a only if the utility fails to have meters on its sources of supply</p>	<p>to qualify for 2: Organize and launch efforts to collect data for determining volume from own sources</p>	<p>to qualify for 4: Locate all water production sources on maps and in the field, launch meter accuracy testing for existing meters, begin to install meters on unmetered water production sources and replace any obsolete/defective meters.</p>	<p>to qualify for 6: Formalize annual meter accuracy testing for all source meters, specify the frequency of testing. Complete installation of meters on unmetered water production sources and complete replacement of all obsolete/defective meters.</p>	<p>Production meter data is logged automatically in electronic format and reviewed at least on a monthly basis with necessary corrections implemented. "Volume from own sources" tabulations include estimate of daily changes in tank/storage facilities. Meter data is adjusted when gross meter errors occur. Meter accuracy testing deems this necessary.</p>	<p>Hourly production meter data is logged automatically & reviewed on at least a weekly basis. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected, and/or error is confirmed by meter accuracy testing. Tank/storage facility elevation changes are automatically used in calculating a balanced volume from own sources. Meter data is corrected on at least a weekly basis.</p>	<p>to qualify for 8: Conduct annual meter accuracy testing and calibration of related instrumentation on all meter installations on a regular basis. Complete project to install new, or replace defective existing, meters so that error production meter population is metered. Repair or replace meters outside of +/- 6% accuracy.</p>	<p>to qualify for 10: Maintain annual meter accuracy testing and calibration of related instrumentation for all meter installations. Repair or replace meters outside of +/- 3% accuracy. Investigate new meter technology; pilot one or more replacements with innovative meters in an attempt to improve meter accuracy.</p>	<p>Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.</p>	<p>Computerized system (SCADA or similar) automatically balances flows from all sources and stores; results are reviewed each business day. Tight accountability controls ensure that all data gaps that occur in the archived flow data are regularly detected and corrected. Regular calibrations between SCADA and source meters ensures minimal data transfer error.</p>	
<p>Water imported:</p> <p>Improvements to attain higher data grading for "Master meter and supply error adjustment" component</p>	<p>Select n/a if the water utility's supply is exclusively from its own water resources (no bulk purchased/imported water)</p>	<p>to qualify for 2: Develop a plan to restructure recordkeeping system to capture all flow data, set a procedure to review flow data on a daily basis to detect input errors. Obtain more reliable information about existing meters by conducting field inspections of meters and obtaining manufacturer and obtaining manufacturer literature.</p>	<p>to qualify for 4: Install automatic data logging equipment on production meters. Complete installation of level instrumentation at all tank/storage facilities and include tank level data in automatic calculation routine in a computerized system. Construct a computerized testing or spreadsheet to archive input volume, tank/storage volume changes and interconnections. Review "Water Supplied" volume for the distribution system. Set a procedure to review this data on a monthly basis to detect gross anomalies and data gaps.</p>	<p>to qualify for 6: Refine computerized data collection and archive to include hourly production meter data that is reviewed at least on a weekly basis to detect specific data anomalies and gaps. Use daily net storage change to balance flows in calculating "Water Supplied" volume. Necessary corrections to data errors are implemented on a weekly basis.</p>	<p>to qualify for 8: Ensure that all flow data is collected and archived on at least an hourly basis. All data is reviewed and detected errors corrected each business day. Tank/storage levels variations are employed in calculating balanced "Water Supplier" component. Adjust production meter data for gross error and inaccuracy confirmed by testing.</p>	<p>to qualify for 10: Link all production and tank/storage facility elevation change data to a Supervisory Control & Data Acquisition (SCADA) System, or similar computerized monitoring/control system, and establish automatic flow balancing algorithm and regularly calibrate between SCADA and source meters. Data is reviewed and corrected each business day.</p>	<p>to qualify for 10: Monitor meter innovations for development of more accurate and less expensive flow meters. Consider replacement of meters to improve performance outside of desired accuracy limits. Stay abreast of new and more accurate water level instruments and better record tank/storage levels and archive the variations in storage volume. Keep current with SCADA and data management systems to ensure that archived data is well-managed and error free.</p>	<p>100% of imported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually for all meter installations, with less than 10% of accuracy tests found outside of +/- 3% accuracy.</p>	<p>100% of imported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually, with less than 10% of meters are found outside of +/- 6% accuracy.</p>	<p>Conditions between 8 and 10</p>	<p>Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Continue to conduct calibration of related instrumentation on a semi-annual basis. Investigate replacement meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.</p>
<p>Water imported:</p> <p>Improvements to attain higher data grading for "Water Imported Volume" component</p>	<p>Select n/a if the water utility's supply is exclusively from its own water resources (no bulk purchased/imported water)</p>	<p>Less than 25% of imported water sources are metered, remaining sources are estimated. No regular meter accuracy testing</p>	<p>25% - 50% of imported water sources are metered, other sources estimated. No regular meter accuracy testing</p>	<p>Conditions between 2 and 4</p>	<p>50% - 75% of imported water sources are metered, other sources estimated. Occasional meter accuracy testing conducted</p>	<p>Conditions between 4 and 6</p>	<p>At least 75% of imported water sources are metered, meter accuracy testing and/or electronic calibration of related instrumentation is conducted annually for all meter installations. Less than 25% of tested meters are found outside of +/- 6% accuracy.</p>	<p>100% of imported water sources are metered, meter accuracy testing and electronic calibration of related instrumentation is conducted semi-annually, with less than 10% of meters are found outside of +/- 6% accuracy.</p>	<p>Conditions between 8 and 10</p>	<p>to qualify for 10: Conduct meter accuracy testing for all meters on a semi-annual basis, along with calibration of all related instrumentation. Repair or replace meters outside of +/- 3% accuracy. Investigate new meter technology; pilot one or more replacements with innovative meters in an attempt to improve meter accuracy.</p>	<p>Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Continue to conduct calibration of related instrumentation on a semi-annual basis. Investigate replacement meters outside of +/- 3% accuracy. Continually investigate/pilot improving metering technology.</p>

Grading >>>	n/a	1	2	3	4	5	6	7	8	9	10
Water imported master meter and supply error adjustment	Select n/a if the imported water supply is unmetered, with imported water quantities estimated on the billing invoices sent by the Exporter to the purchasing Utility.	Inventory information on imported meters and paper records of measured volumes exist but are incomplete and/or in a very crude condition; data error cannot be determined. Written agreements with water Exporter(s) are missing or written in vague language concerning meter management and testing.	No automatic datalogging of imported supply volumes; daily readings are scribed on paper records without any accountability controls to confirm data accuracy and the absence of errors and data gaps in recorded volumes. Written agreement requires meter accuracy testing but is vague on the details of how and who conducts the testing.	Imported supply metered flow data is logged automatically & reviewed on a monthly basis by the Exporter with necessary corrections implemented. Meter data is adjusted by the Exporter when gross data errors are detected. A coherent data trail exists for this process to protect both the selling and the purchasing Utility. Written agreement exists and clearly states requirements and roles for meter accuracy testing and data management.	Hourly imported supply metered data is logged automatically & reviewed on at least a weekly basis by the Exporter. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected, and to correct for error confirmed by meter accuracy testing. Any data gaps in the archived data are detected and corrected during the weekly review. A coherent data trail exists for this process to protect both the selling and the purchasing Utility.	Hourly imported supply metered data is logged automatically & reviewed on at least a weekly basis by the Exporter. Data is adjusted to correct gross error when meter/instrumentation equipment malfunction is detected, and to correct for error confirmed by meter accuracy testing. Any data gaps in the archived data are detected and corrected during the weekly review. A coherent data trail exists for this process to protect both the selling and the purchasing Utility.	Continuous imported supply metered flow data is logged automatically & reviewed each business day by the Exporter. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling and purchasing Utility at least once every five years.	Continuous imported supply metered flow data is logged automatically & reviewed each business day by the Exporter. Results of all meter accuracy tests and data corrections should be available for sharing between the Exporter and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreement between the selling and the purchasing Utility, at least every five years.	Continuous imported supply metered flow data is logged automatically & reviewed each business day by the Exporter. Results of all meter accuracy tests and data corrections should be available for sharing between the Exporter and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreement between the selling and the purchasing Utility, at least every five years.	Continuous imported supply metered flow data is logged automatically & reviewed each business day by the Exporter. Results of all meter accuracy tests and data corrections should be available for sharing between the Exporter and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreement between the selling and the purchasing Utility, at least every five years.	Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the Exporter. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling and purchasing Utility at least once every five years.
Improvements to attain higher data grading for "Water Imported master meter and supply error adjustment" component.		Develop a plan to restructure recordkeeping system to capture all flow data, set a procedure to review input errors. Obtain more reliable information about testing meters by conducting field inspections of meters and related instrumentation, and obtaining manufacturer information. Review the written agreement between the selling and purchasing Utility.	Install automatic datalogging equipment on imported supply meters. Set a procedure to review the data on a monthly basis to detect gross anomalies and data gaps. Launch discussions with the Exporter to jointly review terms of the written agreements regarding meter accuracy testing and data management; revise the terms as necessary.	Refine computerized data collection and archive to include hourly imported supply metered flow data that is reviewed at least on a weekly basis to detect specific data anomalies and gaps. Make necessary corrections to errors/data errors on a weekly basis.	to qualify for 6: Ensure that all imported supply metered flow data is collected and archived on at least an hourly basis. All data is reviewed and error/data gaps are corrected each business day.	to qualify for 8: Conduct accountability checks to confirm that all imported supply metered data is reviewed and corrected each business day by the Exporter. Results of all meter accuracy tests and data corrections should be available for sharing between the Exporter and the purchasing Utility. Establish a schedule for a regular review and updating of the contractual language in the written agreement between the selling and the purchasing Utility, at least every five years.	to qualify for 10: Monitor meter innovations for development of more accurate and less expensive flowmeters, work with the Exporter to help identify meter replacement needs. Keep communication lines with Exporters open and maintain productive relations. Keep the written agreement current with clear and explicit language that meets the ongoing needs of all parties.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted semi-annually, less than 10% of meters are found outside of +/- 3% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted semi-annually, less than 10% of meters are found outside of +/- 3% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted semi-annually, less than 10% of meters are found outside of +/- 3% accuracy.	Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Consider utility testing to improve metering technology.
Water Exported.	Select n/a if the water utility sells no bulk water utilities (no exported water sales)	Less than 25% of exported water sources are metered, remaining sources are estimated. No regular meter accuracy testing.	25% - 50% of exported water sources are metered; other sources are estimated. No regular meter accuracy testing.	50% - 75% of exported water sources are metered, other sources are estimated. Occasional meter accuracy testing conducted.	At least 75% of exported water sources are metered, meter accuracy testing and/or electronic calibration conducted annually. Less than 25% of tested meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.	100% of exported water sources are metered, meter accuracy testing and instrumentation is conducted annually, less than 10% of meters are found outside of +/- 6% accuracy.
Improvements to attain higher data grading for "Water Exported Volume" component. (Note: usually, if the water utility being audited sells only bulk water, the responsibility of the utility exporting the water installation measuring the Exported volume. The utility exporting the water should ensure that adequate meter upkeep takes place and an accurate measure of the Water Exported volume is quantified.)		Review bulk water sales agreements; confirm requirements for use & upkeep of accurate metering. Identify needs to install new, or replace defective meters as needed.	Locate all exported water sources on maps and in field; launch meter accuracy testing for existing meters, begin to install meters on unmetered exported water interconnections and replace obsolete/defective meters.	Formalize annual meter accuracy testing for all exported water meters. Continue installation of meters on unmetered exported water interconnections and replacement of obsolete/defective meters.	Complete project to install new, or replace defective, meters on all exported water interconnections. Maintain annual meter accuracy testing for all exported water meters. Repair or replace meters outside of +/- 6% accuracy.	to qualify for 8: Maintain annual meter accuracy testing for all meters. Repair or replace meters outside of +/- 3% accuracy. Consider utility testing to improve meter accuracy.	to qualify for 10: Standardize meter accuracy test frequency to semi-annual, or more frequent, for all meters. Repair or replace meters outside of +/- 3% accuracy. Consider utility testing to improve metering technology.	Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the utility selling (exporting) the water. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling Utility and purchasing Utility at least once every five years.	Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the utility selling (exporting) the water. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling Utility and purchasing Utility at least once every five years.	Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the utility selling (exporting) the water. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling Utility and purchasing Utility at least once every five years.	Computerized system (SCADA or similar) automatically records data which is reviewed each business day by the utility selling (exporting) the water. Tight accountability controls ensure that all error/data gaps that occur in the archived flow data are quickly detected and corrected. A reliable data trail exists and contract provisions for meter testing and data management are reviewed by the selling Utility and purchasing Utility at least once every five years.



Average Length of Customer Service Line

The three figures shown on this worksheet display the assignment of the Average Length of Customer Service Line, L_p , for the three most common piping configurations.




Figure 1 shows the configuration of the water meter outside of the customer building next to the curb stop valve. In this configuration $L_p = 0$ since the distance between the curb stop and the customer metering point is essentially zero.

Figure 2 shows the configuration of the customer water meter located inside the customer building, where L_p is the distance from the curb stop to the water meter.

Figure 3 shows the configuration of an unmetred customer building, where L_p is the distance from the curb stop to the first point of customer water consumption, or, more simply, the building line.

In any water system the L_p will vary notably in a community of different structures, therefore the average L_p value is used and this should be approximated or calculated if a sample of service line measurements has been gathered.

[Click for more information](#)





AWWA Free Water Audit Software: Definitions

WAS v5.0

American Water Works Association
Copyright © 2014. All Rights Reserved

Item Name	Description
<p>Apparent Losses</p> <p>Find</p>	<p>= unauthorized consumption + customer metering inaccuracies + systematic data handling errors</p> <p>Apparent Losses include all types of inaccuracies associated with customer metering (worn meters as well as improperly sized meters or wrong type of meter for the water usage profile) as well as systematic data handling errors (meter reading, billing, archiving and reporting), plus unauthorized consumption (theft or illegal use).</p> <p>NOTE: Over-estimation of Apparent Losses results in under-estimation of Real Losses. Under-estimation of Apparent Losses results in over-estimation of Real Losses.</p>
<p>AUTHORIZED CONSUMPTION</p> <p>Find</p>	<p>= billed water exported + billed metered + billed unmetered + unbilled metered + unbilled unmetered consumption</p> <p>The volume of metered and/or unmetered water taken by registered customers, the water utility's own uses, and uses of others who are implicitly or explicitly authorized to do so by the water utility; for residential, commercial, industrial and public-minded purposes.</p> <p>Typical retail customers' consumption is tabulated usually from established customer accounts as billed metered consumption, or - for unmetered customers - billed unmetered consumption. These types of consumption, along with billed water exported, provide revenue potential for the water utility. Be certain to tabulate the water exported volume as a separate component and do not "double-count" it by including in the billed metered consumption component as well as the water exported component.</p> <p>Unbilled authorized consumption occurs typically in non-account uses, including water for fire fighting and training, flushing of water mains and sewers, street cleaning, watering of municipal gardens, public fountains, or similar public-minded uses. Occasionally these uses may be metered and billed (or charged a flat fee), but usually they are unmetered and unbilled. In the latter case, the water auditor may use a default value to estimate this quantity, or implement procedures for the reliable quantification of these uses. This starts with documenting usage events as they occur and estimating the amount of water used in each event. (See Unbilled unmetered consumption)</p>
<p>View Service Connection Diagram</p> <p>Average length of customer service line</p> <p>Find</p>	<p>This is the average length of customer service line, Lp, that is owned and maintained by the customer; from the point of ownership transfer to the customer water meter, or building line (if unmetered). The quantity is one of the data inputs for the calculation of Unavoidable Annual Real Losses (UARL), which serves as the denominator of the performance indicator: Infrastructure Leakage Index (ILI). The value of Lp is multiplied by the number of customer service connections to obtain a total length of customer owned piping in the system. The purpose of this parameter is to account for the unmetered service line infrastructure that is the responsibility of the customer for arranging repairs of leaks that occur on their lines. In many cases leak repairs arranged by customers take longer to be executed than leak repairs arranged by the water utility on utility-maintained piping. Leaks run longer - and lose more water - on customer-owned service piping, than utility owned piping.</p> <p>If the customer water meter exists near the ownership transfer point (usually the curb stop located between the water main and the customer premises) this distance is zero because the meter and transfer point are the same. This is the often encountered configuration of customer water meters located in an underground meter box or "pit" outside of the customer's building. The Free Water Audit Software asks a "Yes/No" question about the meter at this location. If the auditor selects "Yes" then this distance is set to zero and the data grading score for this component is set to 10.</p> <p>If water meters are typically located inside the customer premise/building, or properties are unmetered, it is up to the water auditor to estimate a system-wide average Lp length based upon the various customer land parcel sizes and building locations in the service area. Lp will be a shorter length in areas of high density housing, and a longer length in areas of low density housing and varied commercial and industrial buildings. General parcel demographics should be employed to obtain a composite average Lp length for the entire system.</p> <p>Refer to the "Service Connection Diagram" worksheet for a depiction of the service line/metering configurations that typically exist in water utilities. This worksheet gives guidance on the determination of the Average Length, Lp, for each configuration.</p>
<p>Average operating pressure</p> <p>Find</p>	<p>This is the average pressure in the distribution system that is the subject of the water audit. Many water utilities have a calibrated hydraulic model of their water distribution system. For these utilities, the hydraulic model can be utilized to obtain a very accurate quantity of average pressure. In the absence of a hydraulic model, the average pressure may be approximated by obtaining readings of static water pressure from a representative sample of fire hydrants or other system access points evenly located across the system. A weighted average of the pressure can be assembled; but be sure to take into account the elevation of the fire hydrants, which typically exist several feet higher than the level of buried water pipelines. If the water utility is compiling the water audit for the first time, the average pressure can be approximated, but with a low data grading. In subsequent years of auditing, effort should be made to improve the accuracy of the average pressure quantity. This will then qualify the value for a higher data grading.</p>
<p>Billed Authorized Consumption</p>	<p>All consumption that is billed and authorized by the utility. This may include both metered and unmetered consumption. See "Authorized Consumption" for more information.</p>
<p>Billed metered consumption</p> <p>Find</p>	<p>All metered consumption which is billed to retail customers, including all groups of customers such as domestic, commercial, industrial or institutional. It does NOT include water supplied to neighboring utilities (water exported) which is metered and billed. Be sure to subtract any consumption for exported water sales that may be included in these billing roles. Water supplied as exports to neighboring water utilities should be included only in the Water Exported component. The metered consumption data can be taken directly from billing records for the water audit period. The accuracy of yearly metered consumption data can be refined by including an adjustment to account for customer meter reading lag time since not all customer meters are read on the same day of the meter reading period. However additional analysis is necessary to determine the lag time adjustment value, which may or may not be significant.</p>
<p>Billed unmetered consumption</p> <p>Find</p>	<p>All billed consumption which is calculated based on estimates or norms from water usage sites that have been determined <u>by utility policy</u> to be left unmetered. This is typically a very small component in systems that maintain a policy to meter their customer population. However, this quantity can be the key consumption component in utilities that have not adopted a universal metering policy. This component should NOT include any water that is supplied to neighboring utilities (water exported) which is unmetered but billed. Water supplied as exports to neighboring water utilities should be included only in the Water Exported component.</p>

Item Name	Description
<p>Customer metering inaccuracies</p> <p>Find</p>	<p>Apparent water losses caused by the collective under-registration of customer water meters. Many customer water meters gradually wear as large cumulative volumes of water are passed through them over time. This causes the meters to under-register the flow of water. This occurrence is common with smaller residential meters of sizes 5/8-inch and 3/4 inch after they have registered very large cumulative volumes of water, which generally occurs only after periods of years. For meters sized 1-inch and larger - typical of multi-unit residential, commercial and industrial accounts - meter under-registration can occur from wear or from the improper application of the meter; i.e. installing the wrong type of meter or the wrong size of meter, for the flow pattern (profile) of the consumer. For instance, many larger meters have reduced accuracy at low flows. If an oversized meter is installed, most of the time the routine flow will occur in the low flow range of the meter, and a significant portion of it may not be registered. It is important to properly select and install all meters, but particularly large customer meters, size 1-inch and larger.</p> <p>The auditor has two options for entering data for this component of the audit. The auditor can enter a percentage under-registration (typically an estimated value), this will apply the selected percentage to the two categories of metered consumption to determine the volume of water not recorded due to customer meter inaccuracy. Note that this percentage is a composite average inaccuracy for all customer meters in the entire meter population. The percentage will be multiplied by the sum of the volumes in the Billed Metered and Unbilled Metered components. Alternatively, if the auditor has substantial data from meter testing activities, he or she can calculate their own loss volumes, and this volume may be entered directly.</p> <p>Note that a value of zero will be accepted but an alert will appear asking if the customer population is unmetered. Since all metered systems have some degree of inaccuracy, a positive value should be entered. A value of zero in this component is valid only if the water utility does not meter its customer population.</p>
<p>Customer retail unit cost</p> <p>Find</p>	<p>The Customer Retail Unit Cost represents the charge that customers pay for water service. This unit cost is applied routinely to the components of Apparent Loss, since these losses represent water reaching customers but not (fully) paid for. Since most water utilities have a rate structure that includes a variety of different costs based upon class of customer, a weighted average of individual costs and number of customer accounts in each class can be calculated to determine a single composite cost that should be entered into this cell. Finally, the weighted average cost should also include additional charges for sewer, storm water or biosolids processing, <u>but only</u> if these charges are based upon the volume of potable water consumed.</p> <p>For water utilities in regions with limited water resources and a questionable ability to meet the drinking water demands in the future, the Customer Retail Unit Cost might also be applied to value the Real Losses; instead of applying the Variable Production Cost to Real Losses. In this way, it is assumed that every unit volume of leakage reduced by leakage management activities will be sold to a customer.</p> <p>Note: the Free Water Audit Software allows the user to select the units that are charged to customers (either \$/1,000 gallons, \$/hundred cubic feet, or \$/1,000 litres) and automatically converts these units to the units that appear in the "WATER SUPPLIED" box. The monetary units are United States dollars, \$.</p>
<p>Infrastructure Leakage Index (ILI)</p> <p>Find</p>	<p>The ratio of the Current Annual Real Losses (Real Losses) to the Unavoidable Annual Real Losses (UARL). The ILI is a highly effective performance indicator for comparing (benchmarking) the performance of utilities in operational management of real losses.</p>
<p>Length of mains</p> <p>Find</p>	<p>Length of all pipelines (except service connections) in the system starting from the point of system input metering (for example at the outlet of the treatment plant). It is also recommended to include in this measure the total length of fire hydrant lead pipe. Hydrant lead pipe is the pipe branching from the water main to the fire hydrant. Fire hydrant leads are typically of a sufficiently large size that is more representative of a pipeline than a service connection. The average length of hydrant leads across the entire system can be assumed if not known, and multiplied by the number of fire hydrants in the system, which can also be assumed if not known. This value can then be added to the total pipeline length. Total length of mains can therefore be calculated as:</p> <p>Length of Mains, miles = (total pipeline length, miles) + [{(average fire hydrant lead length, ft) x (number of fire hydrants)} / 5,280 ft/mile]</p> <p style="text-align: center;">or</p> <p>Length of Mains, kilometres = (total pipeline length, kilometres) + [{(average fire hydrant lead length, metres) x (number of fire hydrants)} / 1,000 metres/kilometre]</p>
<p>NON-REVENUE WATER</p> <p>Find</p>	<p>= Apparent Losses + Real Losses + Unbilled Metered Consumption + Unbilled Unmetered Consumption. This is water which does not provide revenue potential to the utility.</p>
<p>Number of active AND inactive service connections</p> <p>Find</p>	<p>Number of customer service connections, extending from the water main to supply water to a customer. Please note that this includes the actual number of distinct piping connections, including fire connections, whether active or inactive. This may differ substantially from the number of customers (or number of accounts). Note: this number does not include the pipeline leads to fire hydrants - the total length of piping supplying fire hydrants should be included in the "Length of mains" parameter.</p>
<p>Real Losses</p> <p>Find</p>	<p>Physical water losses from the pressurized system (water mains and customer service connections) and the utility's storage tanks, up to the point of customer consumption. In metered systems this is the customer meter, in unmetered situations this is the first point of consumption (stop tap/tap) within the property. The annual volume lost through all types of leaks, breaks and overflows depends on frequencies, flow rates, and average duration of individual leaks, breaks and overflows.</p>
<p>Revenue Water</p>	<p>Those components of System Input Volume that are billed and have the potential to produce revenue.</p>
<p>Service Connection Density</p> <p>Find</p>	<p>=number of customer service connections / length of mains</p>



**AWWA Free Water Audit Software:
Determining Water Loss Standing**

WAS v5.0
American Water Works Association.
Copyright © 2014. All Rights Reserved.

Water Audit Report for: **California City (1510032)**
Reporting Year: **2017** 1/2017 - 12/2017
Data Validity Score: **53**

Water Loss Control Planning Guide

		Water Audit Data Validity Level / Score			
Functional Focus Area	Level I (0-25)	Level II (26-50)	Level III (51-70)	Level IV (71-90)	Level V (91-100)
Audit Data Collection	Launch auditing and loss control team; address production metering deficiencies	Analyze business process for customer metering and billing functions and water supply operations. Identify data gaps.	Establish/revise policies and procedures for data collection	Refine data collection practices and establish as routine business process	Annual water audit is a reliable gauge of year-to-year water efficiency standing
Short-term loss control	Research information on leak detection programs. Begin flowcharting analysis of customer billing system	Conduct loss assessment investigations on a sample portion of the system: customer meter testing, leak survey, unauthorized consumption, etc.	Establish ongoing mechanisms for customer meter accuracy testing, active leakage control and infrastructure monitoring	Refine, enhance or expand ongoing programs based upon economic justification	Stay abreast of improvements in metering, meter reading, billing, leakage management and infrastructure rehabilitation
Long-term loss control		Begin to assess long-term needs requiring large expenditure: customer meter replacement, water main replacement program, new customer billing system or Automatic Meter Reading (AMR) system.	Begin to assemble economic business case for long-term needs based upon improved data becoming available through the water audit process.	Conduct detailed planning, budgeting and launch of comprehensive improvements for metering, billing or infrastructure management	Continue incremental improvements in short-term and long-term loss control interventions
Target-setting			Establish long-term apparent and real loss reduction goals (+10 year horizon)	Establish mid-range (5 year horizon) apparent and real loss reduction goals	Evaluate and refine loss control goals on a yearly basis
Benchmarking			Preliminary Comparisons - can begin to rely upon the Infrastructure Leakage Index (ILI) for performance comparisons for real losses (see below table)	Performance Benchmarking - ILI is meaningful in comparing real loss standing	Identify Best Practices/ Best in class - the ILI is very reliable as a real loss performance indicator for best in class service

For validity scores of 50 or below, the shaded blocks should not be focus areas until better data validity is achieved.

Once data have been entered into the Reporting Worksheet, the performance indicators are automatically calculated. How does a water utility operator know how well his or her system is performing? The AWWA Water Loss Control Committee provided the following table to assist water utilities in gauging an approximate Infrastructure Leakage Index (ILI) that is appropriate for their water system and local conditions. The lower the amount of leakage and real losses that exist in the system, then the lower the ILI value will be.

Note: this table offers an approximate guideline for leakage reduction target-setting. The best means of setting such targets include performing an economic assessment of various loss control methods. However, this table is useful if such an assessment is not possible.

**General Guidelines for Setting a Target ILI
(without doing a full economic analysis of leakage control options)**

Target ILI Range	Financial Considerations	Operational Considerations	Water Resources Considerations
1.0 - 3.0	Water resources are costly to develop or purchase; ability to increase revenues via water rates is greatly limited because of regulation or low ratepayer affordability.	Operating with system leakage above this level would require expansion of existing infrastructure and/or additional water resources to meet the demand.	Available resources are greatly limited and are very difficult and/or environmentally unsound to develop.
>3.0 -5.0	Water resources can be developed or purchased at reasonable expense; periodic water rate increases can be feasibly imposed and are tolerated by the customer population.	Existing water supply infrastructure capability is sufficient to meet long-term demand as long as reasonable leakage management controls are in place.	Water resources are believed to be sufficient to meet long-term needs, but demand management interventions (leakage management, water conservation) are included in the long-term
>5.0 - 8.0	Cost to purchase or obtain/treat water is low, as are rates charged to customers.	Superior reliability, capacity and integrity of the water supply infrastructure make it relatively immune to supply shortages.	Water resources are plentiful, reliable, and easily extracted.
Greater than 8.0	Although operational and financial considerations may allow a long-term ILI greater than 8.0, such a level of leakage is not an effective utilization of water as a resource. Setting a target level greater than 8.0 - other than as an incremental goal to a smaller long-term target - is discouraged.		
Less than 1.0	If the calculated Infrastructure Leakage Index (ILI) value for your system is 1.0 or less, two possibilities exist. a) you are maintaining your leakage at low levels in a class with the top worldwide performers in leakage control. b) A portion of your data may be flawed, causing your losses to be greatly understated. This is likely if you calculate a low ILI value but do not employ extensive leakage control practices in your operations. In such cases it is beneficial to validate the data by performing field measurements to confirm the accuracy of production and customer meters, or to identify any other potential sources of error in the data.		



AWWA Free Water Audit Software: Examples of Completed and Validated Audits

WAS v5.0

American Water Works Association
Copyright © 2014. All Rights Reserved.

Example 1a: Million Gallons:

Example 1b: Million Gallons:

Example 2a: Megalitres:
Reporting Worksheet

Example 2b: Megalitres:
Reporting Worksheet



Example Audit 1a:

AWWA Free Water Audit Software: Reporting Worksheet

WAS v5.0

American Water Works Association
Copyright © 2014. All Rights Reserved.

[Click to access definition](#)
[Click to add a comment](#)

Water Audit Report for: **City of Asheville (01-11-010)**
Reporting Year: **2013** 7/2012 - 6/2013

Please enter data in the white cells below. Where available, metered values should be used; if metered values are unavailable please estimate a value. Indicate your confidence in the accuracy of the input data by grading each component (n/a or 1-10) using the drop-down list to the left of the input cell. Hover the mouse over the cell to obtain a description of the grades

All volumes to be entered as: **MILLION GALLONS (US) PER YEAR**

To select the correct data grading for each input, determine the highest grade where the utility meets or exceeds all criteria for that grade and all grades below it

WATER SUPPLIED

----- Enter grading in column 'E' and 'J' ----->

Volume from own sources:	<input type="text" value="7"/>	<input type="text" value="7,352.880"/>	MG/Yr
Water imported:	<input type="text" value="n/a"/>	<input type="text" value="0.000"/>	MG/Yr
Water exported:	<input type="text" value="n/a"/>	<input type="text" value="0.000"/>	MG/Yr

Master Meter Error Adjustments

Pcnt:	<input type="text" value="3"/>	Value:	<input type="text" value="285.450"/>	MG/Yr
	<input type="text" value=""/>		<input type="text" value=""/>	MG/Yr
	<input type="text" value=""/>		<input type="text" value=""/>	MG/Yr

Enter negative % or value for under-registration
Enter positive % or value for over-registration

WATER SUPPLIED: MG/Yr

AUTHORIZED CONSUMPTION

Billed metered:	<input type="text" value="8"/>	<input type="text" value="4,782.250"/>	MG/Yr
Billed unmetered:	<input type="text" value="n/a"/>	<input type="text" value="0.000"/>	MG/Yr
Unbilled metered:	<input type="text" value="7"/>	<input type="text" value="27.757"/>	MG/Yr
Unbilled unmetered:	<input type="text" value="8"/>	<input type="text" value="157.790"/>	MG/Yr

Unbilled Unmetered volume entered is greater than the recommended default value

AUTHORIZED CONSUMPTION: MG/Yr

Click here: [?](#)
for help using option buttons below

Pcnt:	<input type="text" value=""/>	Value:	<input type="text" value="157.790"/>	MG/Yr
-------	-------------------------------	--------	--------------------------------------	-------

Use buttons to select percentage of water supplied OR value

Pcnt:	<input type="text" value="0.25%"/>	Value:	<input type="text" value=""/>	MG/Yr
-------	------------------------------------	--------	-------------------------------	-------

<input type="text" value="2.26%"/>	<input type="text" value=""/>	MG/Yr
<input type="text" value="0.25%"/>	<input type="text" value=""/>	MG/Yr

WATER LOSSES (Water Supplied - Authorized Consumption)

MG/Yr

Apparent Losses

Unauthorized consumption: MG/Yr

Default option selected for unauthorized consumption - a grading of 5 is applied but not displayed

Customer metering inaccuracies: MG/Yr

Systematic data handling errors: MG/Yr

Default option selected for Systematic data handling errors - a grading of 5 is applied but not displayed

Apparent Losses: MG/Yr

Real Losses (Current Annual Real Losses or CARL)

Real Losses = Water Losses - Apparent Losses: MG/Yr

WATER LOSSES: MG/Yr

NON-REVENUE WATER

NON-REVENUE WATER: MG/Yr

= Water Losses + Unbilled Metered + Unbilled Unmetered

SYSTEM DATA

Length of mains:	<input type="text" value="4"/>	<input type="text" value="1,236.5"/>	miles
Number of active AND inactive service connections:	<input type="text" value="7"/>	<input type="text" value="55,256"/>	conn./mile main
Service connection density:	<input type="text" value="45"/>		conn./mile main

Are customer meters typically located at the curbside or property line?

Average length of customer service line:

(length of service line, beyond the property boundary, that is the responsibility of the utility)

Average length of customer service line has been set to zero and a data grading score of 10 has been applied

Average operating pressure: | psi |

COST DATA

Total annual cost of operating water system:	<input type="text" value="10"/>	<input type="text" value="\$33,630,676"/>	\$/Year
Customer retail unit cost (applied to Apparent Losses):	<input type="text" value="10"/>	<input type="text" value="\$3.22"/>	\$/100 cubic feet (ccf)
Variable production cost (applied to Real Losses):	<input type="text" value="6"/>	<input type="text" value="\$335.94"/>	\$/Million gallons <input type="checkbox"/> Use Customer Retail Unit Cost to value real losses

WATER AUDIT DATA VALIDITY SCORE:

*** YOUR SCORE IS: 72 out of 100 ***

A weighted scale for the components of consumption and water loss is included in the calculation of the Water Audit Data Validity Score

PRIORITY AREAS FOR ATTENTION:

Based on the information provided, audit accuracy can be improved by addressing the following components:

- 1: Volume from own sources
- 2: Variable production cost (applied to Real Losses)
- 3: Unauthorized consumption



Example Audit 1b:

AWWA Free Water Audit Software: System Attributes and Performance Indicators

WAS v5.0

AWWA Free Water Audit Software
Copyright © 2014. All Rights Reserved.

Water Audit Report for: **City of Asheville (01-11-010)**
Reporting Year: **2013** | **7/2012 - 6/2013**

***** YOUR WATER AUDIT DATA VALIDITY SCORE IS: 72 out of 100 *****

System Attributes:

Apparent Losses:	140.844	MG/Yr
+ Real Losses:	1,958.789	MG/Yr
= Water Losses:	2,099.633	MG/Yr

Unavoidable Annual Real Losses (UARL): 794.34 MG/Yr

Annual cost of Apparent Losses: \$606,265

Annual cost of Real Losses: \$658,036 Valued at **Variable Production Cost**
Return to Reporting Worksheet to change this assumption

Performance Indicators:

Financial:

- Non-revenue water as percent by volume of Water Supplied: 32.3%
- Non-revenue water as percent by cost of operating system: 3.9% Real Losses valued at Variable Production Cost

Operational Efficiency:

- Apparent Losses per service connection per day: 6.98 gallons/connection/day
- Real Losses per service connection per day: 97.12 gallons/connection/day
- Real Losses per length of main per day*: N/A
- Real Losses per service connection per day per psi pressure: 0.67 gallons/connection/day/psi

From Above, Real Losses = Current Annual Real Losses (CARL): 1,958.79 million gallons/year

Infrastructure Leakage Index (ILI) [CARL/UARL]: 2.47

* This performance indicator applies for systems with a low service connection density of less than 32 service connections/mile of pipeline



AWWA Water Audit Software Version 5.0 Developed by the Water Loss Control Committee of the American Water Works Association August, 2014

This software is intended to serve as a basic tool to compile a preliminary, or "top-down", water audit. It is recommended that users also refer to the current edition of the AWWA M36 Publication, Water Audits and Loss Control Programs, for detailed guidance on compiling a comprehensive, or "bottom-up", water audit using the same water audit methodology.

DEVELOPED BY:

Andrew Chastain-Howley, PG*, MCSM. Black & Veatch
Will J. Jernigan, P.E. Cavanaugh & Associates, P.A.
George Kunkel, P.E. Philadelphia Water Department
Alain Lalonde, P.Eng. Master Meter Canada Inc.
Ralph Y. McCord, P.E. Louisville Water Company
David A. Sayers Delaware River Basin Commission
Brian M. Skeens, P.E. CH2M HILL
Reinhard Sturm Water Systems Optimization, Inc.
John H. Van Arsdel M.E. Simpson Company, Inc.

REFERENCES:

- Alegre, H., Hirner, W., Baptista, J. and Parena, R. Performance Indicators for Water Supply Services. IWA Publishing 'Manual of Best Practice' Series, 2000. ISBN 1 900222 272
- Kunkel, G. et al, 2003. Water Loss Control Committee Report: Applying Worldwide Best Management Practices in Water Loss Control. Journal AWWA, 95:8:65
- AWWA Water Audits and Loss Control Programs, M36 Publication, 3rd Edition, 2009
- Service Connection Diagrams courtesy of Ronnie McKenzie, WRP Pty Ltd.

VERSION HISTORY:

Version:	Release Date:	Number of Worksheets:	Key Features and Developments
v1	2005/ 2006	5	The AWWA Water Audit Software was piloted in 2005 (v1.0 beta). The early versions (1.x) of the software restricted data entry to units of Million Gallons per year. For each entry into the audit, users identified whether the input was measured or estimated.
v2	2006	5	The most significant enhancement in v2 of the software was to allow the user to choose the volumetric units to be used in the audit, Million Gallons or Thousand Cubic Metres (megalitres) per year. Two financial performance indicators were added to provide feedback to the user on the cost of Real and Apparent losses.
v3	2007	7	In v3, the option to report volumetric units in acre-feet was added. Another new feature in v3 was the inclusion of default values for two water audit components (unbilled unmetered and unauthorized consumption). v3 also included two examples of completed audits in units of million gallons and Megalitres. Several checks were added into v3 to provide instant feedback to the user on common data entry problems, in order to help the user complete an accurate water audit.
v4 - v4.2	2010	10	v4 (and versions 4.x) of the software included a new approach to data grading. The simple "estimated" or "measured" approach was replaced with a more granular scale (typically 1-10) that reflected descriptions of utility practices and served to describe the confidence and accuracy of the input data. Each input value had a corresponding scale fully described in the Grading Matrix tab. The Grading Matrix also showed the actions required to move to a higher grading score. Grading descriptions were available on the Reporting Worksheet via a pop-up box next to each water audit input. A water audit data validity score is generated (max = 100) and priority areas for attention (to improve audit accuracy) are identified, once a user completes the required data grading. A service connection diagram was also added to help users understand the impact of customer service line configurations on water losses and how this information should be entered into the water audit software. An acknowledgements section was also added. Minor bug fixes resulted in the release of versions 4.1 and 4.2. A French language version was also made available for v4.2.
v5	2014	12	In v5, changes were made to the way Water Supplied information is entered into software, with each major component having a corresponding Master Meter Error Adjustment entry (and data grading requirement). This required changes to the data validity score calculation; v5 of the software uses a weighting system that is, in part, proportional to the volume of input components. The Grading Matrix was updated to reflect the new audit inputs and also to include clarifications and additions to the scale descriptions. The appearance of the software was updated in v5 to make the software more user-friendly and several new features were added to provide more feedback to the user. Notably, a dashboard tab has been added to provide more visual feedback on the water audit results and associated costs of Non-Revenue Water. A comments sheet was added to allow the user to track notes, comments and to cite sources used.